

Contents

Section One.....	2
Emergency Response Mission and Goals	2
Section Two	2
System Information.....	2
Basic Description and Location of Facilities:	3
Location of NBWD Water System Facilities:.....	3
Section Three	4
Chain of Command for NBWD Water Department.....	4
Section Four.....	5
Potential Emergency Events	5
Section Five	7
Severity of Emergencies	7
Section Six.....	9
Emergency Notification Contacts	9
Notification Methods	13
Section Seven.....	15
Effective Communication for North Beach Water District.....	15
Designated Spokesperson:	15
Key Messages:	15
Requirements for Issuing Public Notice (WAC 246-290-71001).....	15
Section Eight.....	17
Vulnerability Assessment for North Beach Water District.....	17
Section Nine.....	21
Response Actions for Specific Events	21
Type of Incidents	21

Section One

Emergency Response Mission and Goals

Mission Statement for Emergency Response:

Provide clean, safe quantity and quality of water as directed by the Safe Drinking Water Act and be prepared to respond immediately to a variety of events that could lead to contamination of the water system.

Goal One: -----Quickly identify an emergency and initiate efficient and effective response action.

Goal Two: -----Quickly notify customers and local, state, and federal agencies of the emergency.

Goal Three: ----- Quickly determine if the water is not safe to drink or use and be able to notify and advise customers efficiently and effectively of the situation.

Goal Four: ----- Quickly make corrections and/or repairs and return the system to normal operation.

Section Two

System Information

System DOH Identification Number:----- 63000C

System Name and Mailing Address:----- North Beach Water District
PO Box 618
Ocean Park, WA 98640

System Physical Address:----- North Beach Water District
2212 272nd Street
Ocean Park, WA 98640

Directions to the System:----- Proceed north on Highway 103 to Bay Avenue;
Continue north on Vernon Avenue to 270th Place;
Turn east on 270th Place and proceed to U Street;
Turn north on U Street and proceed to 272nd Street;
Turn east on 272nd Street and proceed to 2212 272nd Street.
The District's Business Office and North Wellfield will be on the south side of 272nd Street.

Full Time Population/Connections Served¹:

Population----- 4010

Service Connections----- 3194

¹ Per the District's Water Facilities Inventory (WFI) (WAC 246-290-480(2)(e))

System Owner:

NBWD is a Special Purpose district authorized under Chapter 57.08 RCW "Water Sewer Districts". NBWD is governed by an elected board of commissioners.

Name, Title, and Contact Information of Person Responsible for Maintaining and Implementing This Emergency Response Plan:-----

William Neal,
General Manager NBWD,
PO Box 618 Ocean Park, WA 98640
360.665.4144 Office
360.244.0068 Cell
bneal@northbeachwater.com

Basic Description and Location of Facilities:

North Beach Water District's source of water is groundwater from two wellfields. The Wellfields are identified as the North Wellfield and the Wiegardt Wellfield. The North Wellfield is located at 2212 272nd Street Ocean Park, WA 98640. The Wiegardt Wellfield is located at 25600 Z Street Ocean Park, WA 98640. Each wellfield has a treatment plant designed to reduce iron, manganese, and arsenic to 50% of the maximum contaminant level (MCL). Treated water is conveyed to reservoirs at each wellfield. Each Wellfield has a booster pump station. The distribution system has only one pressure zone.

Location of NBWD Water System Facilities:

North Wellfield, Treatment Plant, Booster Station, and Reservoirs are located at 2212 272nd Street Ocean Park, WA 98640.

- Step 1. From the intersection of Hwy 103 and Bay Avenue in Ocean Park, proceed east on Bay Avenue approximately 0.3 miles to the intersection of Bay Avenue and U Street;
- Step 2. Turn on U street and proceed north approximately 0.5 miles to the intersection of U Street and 272nd Street;
- Step 3. Turn on to 272nd Street and proceed east approximately 650 feet to 2212 272nd Street;
- Step 4. The facilities are located on the south side of 272nd Street.

South Wellfield, Treatment Plant, Booster Station and Reservoir are located at 25600 Z Street Ocean Park, WA 98640.

- Step 1. From the intersection of Hwy 103 and Bay Avenue in Ocean Park, proceed east on Bay Avenue approximately 0.3 miles to the intersection of Bay Avenue and U Street;
- Step 2. Turn on U street and proceed south approximately 0.6 miles to the intersection of U Street and 250th Street;

Step 3. Turn east on to 250th Street and proceed approximately 0.3 miles to the intersection of 250th Street and Ash Place;

Step 4. Turn north onto Ash Place and proceed approximately 500 feet to the intersection of Ash Place and 252nd Place;

Step 5. Turn east on to 252nd Place and proceed approximately 100 feet then turn north onto gravel driveway;

Step 6. Turn onto gravel driveway and proceed north approximately 700 feet to the facility.

Wiegardt Wellfield is located at 25480 U Street Ocean Park, WA 98640.

Step 1. From the South Wellfield proceed west on gravel driveway, located at the northwest corner of the facility, approximately 600 feet.

Step 2. The Wiegardt Wellfield on the south side of the gravel driveway.

Section Three

Chain of Command for NBWD Water Department

William Neal, General Manager

Office Phone: ----- 360.665.4144

Cell Phone: ----- 360.244.0068

Home Phone: ----- 360.665.3290

Responsible for overall management and decision making for the water system. The General Manager is the lead for managing the emergency, providing information to regulatory agencies, the public and news media. All communications to external parties are to be approved by the General Manager.

John Bell, Office Manager

Office Phone: ----- 360.665.4144

Cell Phone: ----- 360.690.4837

Home Phone: -----

Responsible party in absence of General Manager. The Office Manager will publish approved notifications communications to the public and news media.

Dennis Schweizer, Treatment Plant Operator

Office Phone: ----- 360.665.4144

Cell Phone: ----- 360.244.0047

Home Phone: ----- 360.214.2810

Responsible party in absence of General Manager and Office Manager. The Treatment Plant Operator facilitates repairs along with parts and equipment procurement and communicates with the General Manager with recommendations to address the emergency. The Treatment Plant Operator collects and submits water quality samples to accredited laboratories.

Jonathan Fleming, Crew Leader
Office Phone: ----- 360.665.4144
Cell Phone: ----- 360.244.0083
Home Phone: -----

The Crew Leader directs crews, performing inspections, maintenance and repairs. The Crew Leader would help evaluate facilities during an emergency and communicate with the Treatment Plant Operator with recommendations to repair the emergency.

Board of Commissioners:

Brian Sheldon
Phone: ----- 360.665.2804

Gwen Brake
Phone: ----- 360.244.3961

Glenn Ripley
Phone: ----- 360.665.2843

In the absence of the General Manager, the Board of Commissioners will designate one of the Commissioners or an employee or consultant to make public announcements.

Section Four

Potential Emergency Events

The events listed below may cause water system emergencies. They are arranged from lowest to highest probable risk.

Terrorism Risk:----- Low
Not in a high volatile area

Wellhead Contamination Risk:----- Low
Protected sanitary control areas and two wellfields.

Earthquake Risk:----- Low
May cause Catastrophic damage to facilities.
Earthquakes occur nearly every day in Washington. Most are too small to be felt or cause damage.
Large earthquakes are much less common but can cause significant damage to utilities.

Tsunami Risk: ----- Low
May cause Catastrophic damage to facilities.
The Cascadia Subduction Zone produces great earthquakes that can generate large tsunamis.
The average reoccurrence interval for these great earthquakes is between 400 and 500 years.
The last large tsunami that affected the North Beach Peninsula was 315 years ago.

Backflow Incident Risk: ----- Low
 District has a proactive Cross Connection program.
 The District installed service meters that detect and record even small backflow incidents.
 The District installs a high-quality dual check valve² at each service.

Droughts Risk: ----- Low
 Water Source are deep wells.
 The deep wells are recharged primarily through local precipitation.
 During drought conditions, the deep wells are susceptible to saltwater intrusion.

Flood Risk: ----- Low
 Heavy rain is common on the North Beach Peninsula.
 Storm water readily drains to the Pacific Ocean and Willapa Bay.

Ground Slides/Liquefaction Risk: ----- Low
 Ground Movement will result in main breaks.
 Liquefaction due to a Cascadia Subduction Zone earthquake is low to moderate³.

Construction Accident Risk: ----- Medium
 Contractors and other utility crews damage water system facilities from time to time.

Vandalism Risk: ----- Medium
 Most facilities are protected by security fencing.
 All buildings have secure locks and adequate lighting.

Deferred Maintenance Risk: ----- Medium
 Deferred maintenance is postponing repair or replacement of infrastructure that has reached its useful life expediency.
 Deferred maintenance will result failures that can interrupt, impede, or prevent normal operations.

High Winds Risk: ----- Medium
 May cause minor to catastrophic damage to facilities
 Extreme storms (gusts from 65-74 mph) occur once every 5 to 10 years.
 Phenomenal storms (gusts 75 mph and greater) occur once every 25-50 years.

Distribution Contamination Risk: ----- Medium
 A contaminated water distribution system may cause illness or death.
 The water distribution system is aging and not well documented as to size placement and pipe type.
 Distribution system valves and hydrants are old and many no longer function well.
 Contrary to Washington State Law (WAC 246-272A-0210),
 Pacific County DCD allows septic drain fields to be located less than 10 feet from water mains.

² American Society of Safety Engineers (ASSE) standard 1024-2017.

³ WASHINGTON DIVISION OF GEOLOGY AND EARTH RESOURCES REPORT OF INVESTIGATIONS 37

Section Five

Severity of Emergencies

Level I Emergency

NBWD considers the following types of incidents to be Level I Emergencies:

- Meter failures (service meters, source meters, master meters)
- Mechanical failures at pumping stations
- Reservoir signal failures
- Minor vandalism or storm damage
- Service line leaks (laterals from main to meter)

NBWD has trained personnel either working or on call to handle these problem twenty-four hours a day, seven days a week. Personnel are notified from our continually manned Dispatch Center.

Level I - Normal (Routine) Emergency: The system experiences a normal emergency, such as a service line break or power outage. System personnel can handle the problem with minimal outside assistance. In these situations, it is not likely that public health will be immediately jeopardized. Normal events can likely be resolved within 24-48 hours.

Level II Emergency

NBWD considers the following types of incidents to be Level II Emergencies:

- Distribution main breaks
- Positive coliform sample
- Major vandalism or storm damage

Level II - Minor Emergency (Alert Status): The system experiences minor disruption in supply or has indications of possible contamination where it may need to coordinate with DOH and consider issuing a health advisory to customers. In these types of emergencies, public health may be jeopardized, so it is important for system personnel to be on alert and initiate a quick response. Minor emergencies can usually be resolved within 72 hours.

Level III Emergency

NBWD considers the following types of incidents to be Level III Emergencies A health advisory is required and Department of Health must be notified:

- An acute confirmed, coliform maximum contamination level or E. coli/fecal positive sample.
- A confirmed sample of another primary contaminant.
- A system failure resulting in water shortage.
- Transmission main break
- Loss of source

Level III - Significant Emergency: The system experiences significant mechanical or contamination problems where disruption in supply is inevitable and issuance of a health advisory is needed to protect public health. Major emergencies should be reported to DOH as soon as possible to determine the best available means to protect customers health. System personnel are directed to the situation, and outside entities are requested to aid in the response. Major emergencies may require more than 72 hours to resolve.

Level IV Emergency

NBWD considers the following types of incidents to be Level IV Emergencies A health advisory is required and Department of Health must be notified:

- Natural disaster that results in catastrophic damage to system facilities
- Terrorism attack
- Loss of more than one source.

Level IV - Catastrophic Disaster/Major Emergency: The system experiences major damage or contamination from a natural disaster, an accident, or an act of terrorism. These incidents usually require immediate notification of local law enforcement and local emergency management services. Immediate issuance of health advisories and declaration of water supply emergencies are critical to protect public health. These events often take several days or weeks to resolve before the system returns to normal operation.

Section Six

Emergency Notification Contacts

Health/Ecology Departments

Department of Health Southwest Regional Office of Drinking Water

Office:.....360.236.3030
Fax:.....360.236.3029
24 Hr. Emergency:877.481.4901
Andy Anderson, P.E.:.....360.236.3025 – Regional Manager
Kay Rottell:360.236.3037 – Assistant Regional Manager
Teresa Walker P.E.:.....360.236.3032 – Regional Engineer (Pacific County)
Charese Gainor:.....360.236.3045 – Coliform Water Quality Monitoring Program
Sophia Petro:360.236.3046 – Chemical Water Quality Monitoring Program
Denise Miles:.....360.236.3028 – Sanitary Survey Program
Gael Kantz:.....360.236.3027 – Technical Assistance Coordinator

Department of Ecology

Southwest Regional Office:.....360.407.6300
24 Hr. Emergency:800.645.7911
Scott Malone.:360.407.6648 – Well Construction Coordinator Statewide
John Pearch:360.407.0297 – Well Construction Coordinator SW Region
Eva Richards.:360.407.6643 – Environmental Specialist Metered Water Use
Tammy Hall:.....360.236.3045 – Water Rights Examiner – SW Region

Pacific County – Department of Environmental Health

Office:.....360.642.9356
Fax:.....360.875.9304

Police/Fire/Emergency Medical Services

Washington State Patrol

Office:.....360.536.4000 – Statewide
Emergency800.283.7808 – 24 hours
District Eight - Naselle360.484.3130 – Mon – Fri 8 am – 4 p.m.

Federal Bureau of Investigation

Seattle Regional Office:206.622.0460 – Statewide
Olympia Resident Agency.....360.622.0460 – Pacific County

Pacific County – Emergency Management Agency

Scott McDougall:360.642.93387 – PCEMA Director

Pacific County – Sheriff’s Office

Office:.....360.642.9404 - Mon – Fri 8 am – 5 p.m.

24 Hr. Emergency:360.642.9397 -

Pacific County – Fire District #1 – EMS Services

Office:.....360.665.4451

Fax:360.665.4909

24 Hr. Emergency:9-1-1

Local Media

Chinook Observer:360.642.8181

KLMY 99.7 FM:503.861.6620

KMUM 91.9 FM503.325.0010

KAST 1370 AM503.861.6620

Neighboring Water Systems

Surfside HOA:360.665.4147 1950 Connections

Oysterville Water Company360.642.5521 69 Connections

City of Ilwaco360.642.3145 680 Connections

City of Long Beach360.642.4421 2073 Connections

Chinook Water District360.777.8131 385 Connections

Anderson RV Park.....360.642.2231 64 Connections

Ocean Bay Mobile & RV Park.....360.665.6933 40 Connections (unapproved)

Pegg’s Trailer Park.....360.642.2451 34 Connections (unapproved)

Ocean Park Retreat Center360.721.9369 33 Connections (unapproved)

Cranberry RV & Trailer Park.....360.957.3548 38 Connections (unapproved)

Dunes Bible Camp.....360.665.5380 26 Connections (unapproved)

Dunes Loomis Lake.....360.665.5380 13 Connections (unapproved)

Shady Dell Condominiums.....360.642.1315 5 Connections

Ocean Spray Cranberries, Inc.....360.642.2563 1 Connection (commercial)

Water Testing Laboratories

BSK Analytical.....360.750.0055 – Emergency 360.619.8248 – Elizabeth Bunge

ALS Global:360.577.7222 – Emergency 360.975.4165 – 360.430.7119

Pacific County360.875.9356 – Emergency 360.589.3598

Utilities

Charter Communication: 800.314.7195
Century Link..... 855.891.4080
PUD 360.642.3191
Utility Locates 811 – 800.424.5555

Fuel Venders

Wilcox & Flegel Oil: 503.397.0130 – Diesel Delivery
Active Enterprises 360.642.2102 – Propane Delivery
Port of the Peninsula 360.665.4547 – Gasoline Pick-up

Mutual Aid Agreements

Surfside HOA 360.665.4147 – Emergency

Electricians

Ford Electric: 360.642.2137 – Emergency
Wadsworth Electric 503.325.5501 – Emergency

Plumbers

Taft Plumbing 360.665.4775 – Emergency
Belk’s Plumbing 360.783.2951 – Emergency

Excavating Contractors

DPR 360.665.4225 – Emergency
Hill & Son 360.665.4447 – Emergency
Woody’s 360.642.4459 – Emergency

Equipment Rental

Clatsop Power..... 503.325.0792 – Emergency
United Rentals 360.425.2350 – Emergency

Pump Repair

PumpTech..... 503.659.6230 – Emergency
Holt Services 253.604.4878 – Emergency

Well Repair

Bison Well Drilling 253.847.7744 – Emergency 253.380.9355 – Darrell Feavel
Holt Services 253.604.4878 – Emergency

Dosing Pumps

TMG Services.....253.779.4160
Emergency253.606.2576 – Brian Yarnell 360.606.4285 – Thomas Gazdik

Scada Programing

The Automation Group541.359.3755 – Emergency 503.488.9443 – Dustin Perket

Local Call List

Customers at High Risk (immunocompromised, home dialysis)

[Enter Name}.....360.
[Enter Name}.....360.
[Enter Name}.....360.
[Enter Name}.....360.
[Enter Name}.....360.
[Enter Name}.....360.
[Enter Name}.....360.

Hospitals/Schools/Clinics

Golden Sands:.....360.665.4815
Family Health Center360.665.3000
Ocean Park Pharmacy360.665.5181
Free by the Sea360.665.4494
Ocean Park Elementary360.665.4815
Rainbow Child Care360.665.0122
Learning Center.....360.665.4367

Restaurants

Thriftway:.....360.665.5222
Jacks Country Store360.665.4989
Bailey's Bakery:360.665.4449
Doc's Tavern360.665.4105
Anita's Coastal Cafe.....360.642.3500
Rusty Spur360.777.3877
Kiss of Mist360.642.3925
Adelaide's Coffee Shoppe.....360.665.6050
Crown Ally Pub.....360.665.5925
Tu Tu's Lunch Wagon360.244.2712
Berry Patch360.665.5551
StreetSide Taco.....360.777.3300

Wholesale Food

Jolly Roger Oyster:.....360.665.4111
Coast Seafood.....360.665.4075
Willapa Bay Shellfish.....360.665.2804

Local Governments

Port of the Peninsula:360.665.4547
Fire District #1.....360.665.4451
Pacific County Health360.642.9356
Office of Drinking Water360.236.3030 – Emergency 877.481.4901

NBWD

William Neal:360.665.3290 – Home 360.244.0068 - Cell
John Bell.....509.690.4837 - Home
Dennis Schweizer360.214.2810 – Home 360.244.0047 Cell
Jonathan Fleming360.244.0083 – Cell
Jake Nesbit360.244.3337 – Home 360.244.0046 Cell
Joshua Maxey360.875.1649 - Cell
Raymond Hall.....360.244.9719 - Cell
Nikkie Hall360.214.0476 - Home
Angela Blakley808.283.4707 – Home
Brian Sheldon360.665.2804 - Commissioner
Gwen Brake360.244.3961 - Commissioner
Glenn Ripley.....360.665.2843 – Commissioner

Notification Methods

Responsible for Notifying Water System Customers:

John Bell – Office Manager (see page 13 for contact information)

Method:

Reverse 911
Web Site
Local Media
Door Hangers
Signs
Reader Boards

Responsible for Alerting Law Enforcement, Office of Drinking Water, Local Health Department:

William Neal – General Manager (see page 13 for contact information)

Method:

Use phone list and deliver the proper message.

Responsible for Contracting Service and Repair Contractors

Dennis Schweizer – Treatment Plant Operator and
Jonathon Fleming – Crew Leader (see page 13 for contact information)

Method:

Notify General Manager of the need for additional help. Contact necessary contractors from Small Works Roster.

Responsible for Contracting Neighboring Water Systems, If Necessary

William Neal – General Manager (see page 13 for contact information)

Method:

In the case of regional contamination or coordination of efforts, use phone list to deliver message.

Responsible for Issuing a Health Advisory

William Neal – General Manager (see page 13 for contact information)

Method:

- Step 1. Mobilize field crew to investigate the problem(s) and make repairs as necessary.
- Step 2. Confer with key staff to verify problem(s)
- Step 3. Consult with ODW staff regarding notification requirements and assistance in resolution of problem(s)
- Step 4. Organize staff to develop message to be delivered to customers.
- Step 5. Mobilize staff to deliver message via door hangers, road signs, reverse 911, and radio message.
- Step 6. Mobilize staff to notify all local health agencies, restaurants, schools, clinics, pharmacies, emergency medical providers, wholesale food processors, customers on the medical alert/life support list.
- Step 7. When the ODW agrees the District has returned to normal operations, notify all customers the emergency is resolved.

Section Seven

Effective Communication for North Beach Water District

Designated Spokesperson:

The General Manager is the Designated public spokesperson for North Beach Water District. All communication with the media, the public, or federal, state, or local agencies will be directed to the General Manager. In the absence of the General Manager, the Board of Commissioners will designate one of the Commissioners as spokesperson for the District.

Key Messages:

Key messages for water customers are

- boil water letters;
- media notification; and
- letter to rescind boiling water.

NBWD has on file EPA Public Notification Handbook EPA-816-R-09-013, 2010. This book shows all information required for issuing public notices and should be referenced before notices are made to the media and/or customers.

Requirements for Issuing Public Notice (WAC 246-290-71001)

Tier 1 Violations and Other Situations Requiring Notice within 24 Hours:

- Violation of the MCL for total coliform, when **fecal coliform or E. coli** are present in the water distribution system, or failure to test for fecal coliform or E. coli when any **repeat sample tests positive for coliform**.
- Violation of the MCL for **nitrate or nitrite**, or when a confirmation sample is not taken within 24 hours of the system's receipt of the first sample showing exceedance of the nitrate or nitrite MCL.
- Occurrence of a **waterborne disease outbreak**, as defined in 40 CFR 141.2, or another waterborne emergency.
- Detection of **E. coli, enterococci, or coliphage** in a **ground water source** sample.
- Other violations or situations with significant potential for serious adverse effects on human health as a result of short-term exposure, as determined by the primacy agency either in its regulations or on a case-by-case basis.

Note: If NBWD has any of these violations or situations, in addition to issuing public notice, we must initiate consultation with the Southwest Regional Office of Drinking Water as soon as practical but within 24 hours after you learn of the violation or serious situation.

Tier 2 Violations and Other Situations Requiring Notice Within 30 Days

- All violations of the MCL, MRDL, and treatment technique (TT) requirements except where Tier 1 notice is required.
- Violations of monitoring requirements where the primacy agency determines that a Tier 2 public notice is required, considering potential health impacts and persistence of the violation.
- Failure to comply with the terms and conditions of any variance or exemption in place.
- Failure to take corrective action within the required timeframe or follow a state approved corrective action plan and schedule for a fecal indicator-positive ground water source sample under the Ground Water Rule.
- Failure to take corrective action within the required timeframe or follow a state approved corrective action plan and schedule for a significant deficiency under the Ground Water Rule.

Tier 3 Violations and Other Situations Requiring Notice Within 1 Year

- Monitoring violations, except where Tier 1 or Tier 2 notice is required, or the primacy agency determines that the violation requires a Tier 2 notice.
- Failure to comply with an established testing procedure, except where Tier 1 notice is required or the primacy agency determines that the violation requires a Tier 2 notice.

Section Eight

Vulnerability Assessment for North Beach Water District

The District's Vulnerability Assessment is a product of our own personal evaluation of our system and a Vulnerability Assessment by “*insert name of consultant*”. The Vulnerability Assessment was completed “*insert date*”. Both assessments were used in our security upgrade recommendations in this Emergency Response Plan.

North Wellfield Facilities:

Office and Facilities Building

Office, Public Meeting Room, Vehicle Storage, Parts and Supplies Storage, Tool Storage

Vulnerability-----Low

Improvements of Mitigating Actions ----- Monitored security system installed

Recommended Improvements:

1. Video surveillance

Shop

Parts and Supplies Storage, Equipment Storage, Tool Storage

Vulnerability-----Medium

Improvements of Mitigating Actions ----- Fenced on three sides

Recommended Improvements:

1. Improve exterior lighting,
2. Install monitored security system,
3. Install video surveillance,
4. install security doors⁴ on the north side of the building.

Booster Building

Booster Pumps, Generator, Water Meters

Vulnerability-----Low

Improvements of Mitigating Actions -----Fenced on all sides

Recommended Improvements:

1. Improved lighting,
2. install LPS 1175 Level SR2 security doors on the north and south side of the building.

Water Treatment Building

Filtration Equipment

Vulnerability-----Low

Improvements of Mitigating Actions -----Fenced on all sides

Recommended Improvements:

1. Improved lighting

⁴ LPS 1175 Level SR2

NWF Well #1

Located inside Booster Building

Vulnerability-----Low

Improvements of Mitigating Actions -----None

Recommended Improvements-----None

NWF Well #4, #5, #6, #7, and #8

Located in the open east of the treatment plant

Vulnerability-----Low

Improvements of Mitigating Actions -----Fenced on all sides. Secure well caps

Recommended Improvements-----None

NWF Reservoirs #1, #2, and #3

Located south of the treatment plant

Vulnerability-----Low

Improvements of Mitigating Actions -----Fenced on all sides

Recommended Improvements-----None

NWF Caterpillar Generator

Located south of the shop

Vulnerability-----Medium

Improvements of Mitigating Actions -----Fenced on all sides

Recommended Improvements:

1. Build an enclosure for the generator to protect from vandalism and elements

Electric Power Connection

Located southeast of the booster building

Vulnerability-----low

Improvements of Mitigating Actions -----Fenced on all sides

Recommended Improvements-----None

Computer Telemetry System

Located in the water treatment building and the booster building

Vulnerability-----low

Improvements of Mitigating Actions -----Fenced on all sides

Recommended Improvements-----None

Wiegert Wellfield Facilities

Wells #1, #2, and #3

Vulnerability-----Low

Improvements of Mitigating Actions ----- Each Well and components are fenced on all sides

Recommended Improvements:

1. Install lighting and video surveillance.

Generator and Propane Tank

Vulnerability-----Low

Improvements of Mitigating Actions -----Fenced on all sides

Recommended Improvements:

1. Install lighting and video surveillance.

Electric Power Connection

Located in the well #1 fenced enclosure

Vulnerability-----low

Improvements of Mitigating Actions -----Fenced on all sides

Recommended Improvements-----None

Computer Telemetry System

Located in the well #1 fenced area

Vulnerability-----low

Improvements of Mitigating Actions -----Fenced on all sides

Recommended Improvements-----None

South Wellfield Facilities

Treatment Plant Building

Booster Station, Generator, Filtration equipment, Records Storage

Vulnerability-----Medium

Improvements of Mitigating Actions -----Installed secure doors on the east side of the building

Recommended Improvements:

1. Install LPS 1175 Level SR2 security doors on the north side of the building,
2. Install outdoor lighting and video surveillance,
3. Install security fencing around the property.

Storage Building

Vulnerability-----Medium

Improvements of Mitigating Actions -----None

Recommended Improvements:

1. Building needs major upgrades to be secure storage facility.

Water Reservoir

Vulnerability-----Medium

Improvements of Mitigating Actions -----None

Recommended Improvements:

1. Install security fencing around the property.

Electric Power Connection

Located on the treatment plant building

Vulnerability----- Medium

Improvements of Mitigating Actions ----- None

Recommended Improvements:

1. Install security fencing around the property.

Computer Telemetry System

Located in the treatment plant area

Vulnerability----- Medium

Improvements of Mitigating Actions ----- None

Recommended Improvements:

1. Install security fencing around the property.

DRAFT

Section Nine

Response Actions for Specific Events

Regardless of the event that results in an emergency the following actions will be taken by the District with limited variations dependent on the situation:

1. Confirm and determine the type and severity of the emergency.
2. Take immediate actions to protect lives, reduce injuries, protect property, and ensure safety.
3. Collaborate with State and local health officials and others when making Public Health Notifications. Follow all state and local rules and regulations and prioritize notification of vulnerable customers.
4. Make repairs based on priority demand.
5. Return the system to normal operation.

Type of Incidents

A. Loss of System Pressure (below 20 psi)

- a. Emergency Concern:
Cross connection contamination due to back flow from back siphonage or back pressure or direct contamination from open pipe.
- b. Potential Causes:
Booster Pump(s) failed, Power/Standby Generator failed, Water main break.
- c. Immediate Actions:
Contact Office of Drinking Water (ODW) for direction, issue boil water notice,
- d. Follow-Up Actions:
Determine the

B. Positive Coliform Bacteria Sample

- a. Emergency Concern:
Coliforms are a broad class of bacteria found in our environment, including the feces of man and other warm-blooded animals. The presence of coliform bacteria in drinking water may indicate a possible presence of harmful, disease-causing organisms.
- b. Potential Causes:
Failed seals on water reservoir penetrations, improper sample collection procedure, contaminated sample collection bottle, insufficient disinfection of components when working on infrastructure.
- c. Potential Response:
Collect repeat samples and collect triggered source samples per the District's Coliform Monitoring Plan. Thoroughly inspect the water system to identify potential sources of contamination. Take corrective action if any potential sources of contamination are

identified. If two or more positive coliform bacteria samples in one month (treatment technique trigger), perform a level one assessment within 30 days.

C. E.coli Maximum Contaminant Level (MCL) violation

- a. Emergency Concern:
E. coli (Escherichia coli) is the name of a bacterium, that lives in the digestive tracts of humans and animals. There are many types of E. coli, and most of them are harmless. But some can cause bloody diarrhea. Some strains of E. coli bacteria may also cause severe anemia or kidney failure, which can lead to death. Other strains of E. coli can cause urinary tract infections or other infections.
- b. Potential Causes:
Failed seals on water reservoir penetrations, improper sample collection procedure, contaminated sample collection bottle, insufficient disinfection of components when working on infrastructure.
- c. Potential Response:
Contact the Office of Drinking Water (ODW) immediately. In consultation with the ODW, issue a boil water notice. Perform a level 2 assessment. Identify all sanitary defects in the water system and make fix them promptly. Disinfect appropriate facilities and take follow-up water samples.

D. Water Main Break

- a. Emergency Concern:
Cross connection contamination due to back flow from back siphonage or back pressure or direct contamination from open pipe.
- b. Potential Causes:
Excessive stress from ground movement, damage during construction, near or past useful life expectancy.
- c. Immediate Actions:
Contact the Office of Drinking Water (ODW) immediately. Determine the type of main break (see ODW publication 331-583 1/1/2017). Take actions to isolate the break and protect life and property.
- d. Notifications
Notify all customers in the area and implement water shortage response in applicable. In consultation with ODW, issue boil water notice. Notify local Fire Department of limited fire protection status.
- e. Follow -up Actions