

NORTH BEACH WATER DISTRICT

GENERAL MANAGERS REPORT

November Meeting - 2024

Well Field Output

<u>October 1, 2024</u>	to	<u>October 31, 2024</u>	NWF Master Meter:	<u>10.3810</u>	mg
			SWF Master Meter:	<u>0.0000</u>	mg
			Total Pumped to Plant:	<u>10.3810</u>	MG

Water Plant Production

<u>September 1, 2024</u>	to	<u>September 30, 2024</u>	NWF Master Meter:	<u>13.0115</u>	mg
			SWF Master Meter:	<u>0.0000</u>	mg
			Accounted for Water:	<u>11.3344</u>	MG
			Total Water Pumped:	<u>13.0115</u>	MG

Metering Period


<u>September 1, 2024</u>	to	<u>September 30, 2024</u>	Total Water Sold :	<u>6.5490</u>	MG
--------------------------	----	---------------------------	---------------------------	----------------------	-----------

September Accounted for Water:


	NWF Backwash :	<u>0.4347</u>	mg
	SWF Backwash :	<u>0.0000</u>	mg
Distribution Flushing, Fire Dept, Pac Co & Waterline Leak Repair's:		<u>4.3200</u>	mg
	NBWD use NWF & SWF:	<u>0.0307</u>	mg
	Total Accounted for Water:	<u>11.3344</u>	MG

	Total Water Treated :	<u>13.0115</u>	MG
	Accounted for Water Used :	<u>11.3344</u>	MG
	Water Sent to Distribution :	<u>9.6635</u>	MG
	Water Sold :	<u>6.5490</u>	MG
	Distribution Leakage :	<u>1.6771</u>	MG
	Percent of Unaccounted for Water :	12.89	%

DSL - Percentage of Lost Water




Water sent to Distribution MG Total sold MG:




Data Period	October 1 -31, 2024		Booster System Data	
			North Wellfield Booster High GPM :	1,272 <i>gpm</i>
			North Wellfield Booster Average GPM :	216 <i>gpm</i>
			North Wellfield High psi:	66 <i>psi</i>
			North Wellfield Average psi:	56 <i>psi</i>
			Total MG Booster pumped to Distribution at NWF:	9.6635 <i>MG</i>
			Total MG Booster pumped to Distribution at SWF:	0 <i>MG</i>
			Total Booster Pumped to Distribution :	9.6635 <i>MG</i>
			South Wellfield Booster High gpm:	156 <i>gpm</i>
			South Wellfield Booster Average gpm:	91 <i>gpm</i>
			South Wellfield Booster High psi:	64 <i>psi</i>
			South Wellfield Booster Average psi:	51 <i>psi</i>
			245th Distribution Pressure Readings :	
			Highest	66 <i>psi</i>
			Lowest	27 <i>psi</i>
			Average	54 <i>psi</i>

Data Period			Accounts Data		
October 1 -31, 2024			Residential Base	\$142,076.42	\$
September 1 - 30, 2024			Residential Usage	\$26,763.75	\$
October 1 -31, 2024			Commercial Base	\$10,465.55	\$
September 1 - 30, 2024			Commercial Usage	\$10,291.19	\$
Residential Accounts	2,802	ea	Fire Flow Rate	\$1,346.65	\$
Commercial Accounts	98	ea	Backflow Assembly Rate	\$455.65	\$
Fire Flow Accounts	4	ea	Other Fees & Charges	\$4,952.56	\$
Backflow Accounts	42	ea	Total:	\$196,351.77	\$


Residential & Commercial Base



Residential & Commercial Usage




Backflow, Residential & Commercial Base & Usage, Fireflow, & Fees




Data Period	October 1 -31, 2024	Operations Data
	Past Due Accounts	249 <i>ea</i>
	Properties with Liens	17 <i>ea</i>
	Accounts Locked Off	2 <i>ea</i>
	Water Main Locates	25 <i>ea</i>
	Water Quality Complaints	0 <i>ea</i>
	Customer Service Calls	41 <i>ea</i>
	Customer Valves Installed	0 <i>ea</i>
	New Services Installed	6 <i>ea</i>
	NBWD Office & Grounds Water Use:	<u><u>0.0307</u></u> <i>MG</i>


Data Period	October 1 -31, 2024		Water Quality Data	
	Coliform Samples Collected	8	<i>ea</i>	
	Coliform Samples Absent	8	<i>ea</i>	
	Coliform Samples Positive	0	<i>ea</i>	
	Coliform Sample Positive E.coli	0	<i>ea</i>	
	NWF Arsenic	7.00	<i>ug/L</i>	
	SWF Arsenic	0.00	<i>ug/L</i>	
	NWF Arsenic Annual Running Average	6.00	<i>ug/L</i>	
	SWF Arsenic Running Annual Average	0.33	<i>ug/L</i>	



Arsenic Monthly Annual Average micrograms per liter (ug/L)



Residential Connections: 3/4" & 1"



General Managers Report for November's Meeting 2024

- The crew has finished up hydrant flushing, this wasn't just hydrants. We've installed 20 new blow offs at dead ends and there's more to install. Made a big difference. The blow offs at the end of ELM took two days to clean up. It had never been flushed that hard with that kind of volume. It really helped the rest of the system. Meaning that the dirty water wasn't consistently dragged throughout the system. It was removed at ELM.
Replacing the old 1" & 1-1/4" blowoffs with 2" buried standpipes from my standpoint is the helping to clean up the system. This will be my focus until we've replaced everyone.

- Line Breaks
Between 242nd PL and 245th ST at Y Lane. The crew responded to a leak observed. Leaking was a service line that had been crushed by tree roots. I was called to the site to find the 2" had been installed 25 feet on private property. We'll move it onto the R.O.W.

At 213th PL, 3" PVC broke in half. Too much of a bind on the pipe is the culprit here.

Broken gate valve stem at 273rd and Park.

- North Well Field has tested at the Maximum Contaminate Level (MCL) 0.010 mg/l or 10 ppb for Arsenic.
During the recent system flushing the system Blending plan was used. This is a cookbook approach that was designed to run the North treatment plant to keep the Arsenic levels below the MCL of 10 parts per billion (ppb).
All flows were achieved by valving down to obtain the designed flow rates. Max flow was 520 gpm atop of 120 sqft of filter area which by design was less than 4.5 gpm/sqft of filter surface area.
Actually (4.33 gpm/sqft).
Attached is the blending plan. I've contacted DOH to start using Ferric Chloride and a soda ash injection to keep the pH up to 7.5
- Budget focus is now the Treatment plants. Looking at the budgeted cost for the South Treatment Plant of \$351,000.00. I expect it to be closer to \$430,000.00. We have enough to fund this project and go for funding for the North Treatment facility which is estimated at \$751,000.00.
- Vehicle cost, I'm seeing \$45,000 & 49,000.00. Checking with state bid and Dave smiths in Idaho, Ford in Warrenton.
- Jack & Alice Day, who purchased the property at 25210 Z PL wanted to purchase another 9' on the east side boundary to the Northeast corner and 20 ft along the north boundary which would be to the trees. He'd pay all costs involved.

October Work Orders

Read/Leave On	6
Turn Off/Lock – Customer Request	4
Turn Off/Lock – Non-Payment	2
Interrogate Meter	8
Locates	25
Unlock/Turn On	8
Test Backflow	7
Miscellaneous	1
Replace Meter Box	0
Low Pressure	1
Check Customer Valves	0
Dirty Water Complaints	0
Replace Meter	0
Install New Service	6
Assist Customer	1
Check For Leak	6
Re-Read Meter	0
Install Customer Control Valve	0
Total	75